



- Accessory for Alpha BSIII Panel Boards
- Trip alarm switch unit to be fitted inside outgoing MCCB accessory compartment. Once fitted this will consume 1 accessory slot inside of the MCCB
- Unit has 1CO contacts
- $I_e = 6A$, $U_e = 240V AC / 250V DC$
- Sends status signals as to whether MCCB power switch contacts are in the tripped position

Product Specification Data		Revision Date: 29/09/2023
Type of accessory/spare part	Other	
Product Standard/s	IEC 61439-2	
CE Conformity	Yes	
WEEE Symbol	Yes	
UKCA Conformity	Yes	

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.