



- Accessory for Alpha BSIII Panel Boards
- Shunt release unit to be fitted inside outgoing MCCB accessory compartment. Once fitted this will consume 3 accessory slots inside of the MCCB
- Must be fitted in accessory slots directly to the left of the toggle mechanism
- Ue 50/60Hz AC = 24V, Ue DC = 24...30V
- When the coil of this device is energised by an external source it will trip the MCCB

#### Product Specification Data

Revision Date: 29/09/2023

Type of accessory/spare part	Other
Product Standard/s	IEC 61439-2
CE Conformity	Yes
WEEE Symbol	Yes
UKCA Conformity	Yes

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.