



- Accessory for Alpha BSIII Panel Boards
- For use with incoming devices starting with 3VA..
- Incoming kit is necessary when selecting switch disconnector or MCCB incoming device
- Supplied complete with all fixings, including clamps shroud and labelling, along with installation instruction

Product Specification Data		Revision Date: 29/09/2023
Type of accessory/spare part	Power current connection	
CE Conformity	Yes	
WEEE Symbol	Yes	
UKCA Conformity	Yes	
Amperage	630 A	
Pole Configuration	TP	
Busbar type	Solid Copper	
Main switch rating	630 A	

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.