



- Accessory for Alpha BSIII Panel Boards
- For use with incoming devices starting with 3VA..
- Incoming kit is necessary when selecting switch disconnector or MCCB incoming device
- Supplied complete with all fixings, including clamps shroud and labelling, along with installation instruction

Product Specification Data

Revision Date: 29/09/2023

Type of accessory/spare part	Power current connection
CE Conformity	Yes
WEEE Symbol	Yes
UKCA Conformity	Yes
Amperage	630 A
Pole Configuration	4P
Busbar type	Solid Copper
Main switch rating	630 A

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.