



- Accessory for Alpha BSIII Panel Boards
- For use with incoming devices starting with 3VA..
- Incoming kit is necessary when selecting switch disconnector or MCCB incoming device
- Supplied complete with all fixings, including clamps shroud and labelling, along with installation instruction

Product Specification Data

Revision Date: 29/09/2023

| | |
|------------------------------|--------------------------|
| Type of accessory/spare part | Power current connection |
| CE Conformity | Yes |
| WEEE Symbol | Yes |
| UKCA Conformity | Yes |
| Amperage | 400 A |
| Pole Configuration | 4P |
| Busbar type | Solid Copper |
| Main switch rating | 400 A |

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.