

List No. NHVA4250CK

Incoming device interconnection kit 250A 4P



- For use with NH VM160 Panel Boards
- For use with incoming devices starting with NHVA..
- Incoming kit is necessary when selecting switch disconnector or MCCB incoming device
- Supplied complete with all fixings, including clamps shroud and labelling, along with installation instruction

Product Specification Data	Revision Date: 31/08/2022
Type of accessory/spare part	Power current connection
CE Conformity	Yes
WEEE Symbol	Yes
UKCA Conformity	Yes
Amperage	250 A
Pole Configuration	4P
Busbar type	Solid Copper
Main switch rating	250 A

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.

