

List No. NMDRS12HI

NH / NM / NMX

12 Way Duplex High Integrity Consumer Unit 100A Main Switch, 80A 30mA RCDs x3, Flexible Configuration



- Full metal duplex enclosure
- Flexible busbar assembly
- 12W High integrity
- 3 x 80A 30mA type A RCCBs

| Product Specification Data | Revision Date: 15/10/2021 |
|--|--|
| Mounting method | Surface mounted (plaster) |
| Number of phases | 1 |
| Protection | Miniature- / earth leakage circuit breaker |
| Total number of groups | 4 |
| Number of poles main switch | 2 |
| Main switch rated current | 100 A |
| Over voltage protection | No |
| Material housing | Steel |
| Degree of protection (IP) | IP2XC |
| Height | 506 mm |
| Width | 241 mm |
| Width in number of modular spacings | 10 |
| Depth | 121 mm |
| Extension possible | No |
| With transparent cover | No |
| Lockable | No |
| Product Standard/s | BS EN 61439-3 |
| Frequency | 50 Hz |
| CE Conformity | Yes |
| WEEE Symbol | Yes |
| UKCA Conformity | Yes |
| Amperage | 100 A |
| Operating Voltage | 230 V |
| Type of Current | AC |
| Consumer Unit Type | High integrity |
| Total final circuit modular ways | 12 |
| Busbar type | Flexible |
| Main switch rating | 100 A |
| Main switch final circuit modular ways | Flexible |

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.

| Product Specification Data (cont) | Revision Date: 15/10/2021 |
|-----------------------------------|---------------------------|
| RCD 1 | 80A 30mA type A |
| RCD 1 final circuit modular ways | Flexible |
| RCD 2 | 80A 30mA type A |
| RCD 2 final circuit modular ways | Flexible |
| RCD 3 | 80A 30mA type A |
| RCD 3 final circuit modular ways | Flexible |
| Colour RAL | 9010 |

Although every effort has been made to ensure accuracy in the compilation of the technical detail within this datasheet, specifications and performance data are constantly changing. Latest details can be obtained from the Electrium website.

