

## VERTICAL STACK LIGHTING AND POWER DISTRIBUTION BOARDS

### INSTALLATION INSTRUCTIONS

CATALOGUE No:-  
18LPV....SL  
18LPV.....ML

**BSEN 61439-3**  
**IEC 61439-3**  
**BSEN 60898-1**  
**BSEN 60947-3**

### Technical Support

Tel: +44 (0) 1543 438310  
Fax: +44 (0) 1543 438311  
Email: [crabtree.technical@electrium.co.uk](mailto:crabtree.technical@electrium.co.uk)

## GENERAL WARNINGS



**DANGER: LIVE PARTS ENCLOSED.** Ensure the unit is installed by a qualified competent person in accordance with all relevant legislation and regulations including building regulations and wiring regulations BS7671. If in doubt contact a qualified competent person.


### **IMPORTANT INFORMATION**

Follow the instructions below before working on or inside the equipment.

- Turn off all power supplies.
- Always use a calibrated volt-sensing device to confirm the power is off.
- Replace all devices, doors and covers before turning on the power to this equipment.
- To avoid ingress of swarf and similar material, always remove gland plates to allow cutting/slotting for cable entries.
- Do not use power screwdrivers on electrical connections.
- Parts of the installation in which the meter kit is to be installed may remain live even when isolated. When working on unit isolate MCB.


**Failure to follow these instructions could result in serious injury or death.**

## Required Tools




## Content

No.	Description	QTY
1	Distribution board	2
2	Incoming box	1
3	Anti-gap joining shield	2
4	M5 nut	12
5	M5 contact washers	24
6	M5 x 12 mm bolt	12



## Assembly (Layout)




Electrium Sales Limited, Walkmill Lane, Cannock, WS11 0XE  
Tel: 01543 455000 Fax: 01543 455001




Waste electrical products should not be disposed of with household waste.  
Please recycle where waste disposal facilities exist.  
Check with your retailer, wholesaler or local authority for recycling advice.

## Assembly (Anti-gap joining shield positioning)



## Assembly (Connections)







### NOTES: –

- Affix supplied MCB warning labels in a clearly visible area in the following places 1) beneath or next to meter MCB and 2) beneath or next to isolator on front shield.
- The maximum load on either MCB board is 100A. Affix supplied derating labels in a prominent position on each board.






# Install (MCBs & RCBOs)

## MCB Assembly



## MCB Removal

## MCB connection



## Installation of RCBOs

- Ensure supply is switched off.
- Loosen all RCBO busbar terminal screws.
- Push RCBO onto appropriate busbar outgoing way making sure that the DIN clip faces towards the busbar assembly.
- Fully tighten busbar connections to a recommended torque of device.
- Connect RCBO Neutral lead to appropriate numbered terminal on the neutral terminal bar.
- Ensure both live and neutral outgoing cables are terminated on the RCBO outgoing terminals.
- Connect white functional earth lead to appropriate terminal on earth terminal bar.



Electrium Sales Limited, Walkmill Lane, Cannock, WS11 0XE  
Tel: 01543 455000 Fax: 01543 455001




Waste electrical products should not be disposed of with household waste.  
Please recycle where waste disposal facilities exist.  
Check with your retailer, wholesaler or local authority for recycling advice.

## Distribution Board Technical Data Information


Main characteristics					
<b>Operating voltage</b>					
					240 V AC to 415 V AC
<b>Operating frequency</b>					
Maximum					50 Hz
<b>Power consumption</b>					
Maximum					≤ 125 A / 30 kW
<b>Degree of protection</b>					
					IP 3XC
<b>Pollution degree</b>					
Environmental conditions to which the panel is intended					2 Minimum
Weight (Kg) – Dimensions (mm)					
Description	Weight	Dimensions			
		Kg	Height (mm)	Width (mm)	Depth (mm)
4 Way Distribution Board	9.6	486	430	155	338 x 404
6 Way Distribution Board	11.3	567	430	155	338 x 485
8 Way Distribution Board	12.7	648	430	155	338 x 566
12 Way Distribution Board	15	810	430	155	338 x 728
16 Way Distribution Board	17.7	891	430	155	338 x 809
20 Way Distribution Board	19.3	997	430	155	338 x 915
24 Way Distribution Board	22.4	1134	430	155	338 x 1052
Incoming Enclosure	3	243	430	155	338 x 167
Operating & storage temperature					
Operating temperature					-5 to +40°C (Average of 24h max)
Storage temperature					-5 to +40°C (Average of 24h max)
Humidity					
At maximum temperature (+40°C)					50%
Connections (Nm)					
Incoming device					2.3 Nm
Earth / Neutral bar					2.3 Nm
Busbar terminal cage					6 Nm
MCB / RCBO					2.3 Nm
For more torque connection settings refer to device manual & meter technical data					




# Meter Wiring for STD Information



# Meter Wiring for MID Information



# Power Wiring Details for MID & STD Information



Electrium Sales Limited, Walkmill Lane, Cannock, WS11 0XE  
Tel: 01543 455000 Fax: 01543 455001

LF1730\_2



Waste electrical products should not be disposed of with household waste.  
Please recycle where waste disposal facilities exist.  
Check with your retailer, wholesaler or local authority for recycling advice.



# STD Meter Technical Data Information

## Main characteristics

### Operating voltage

Minimum	40 V AC
Maximum	460 V AC

### Operating frequency

Minimum	45 Hz
Maximum	65 Hz

### Power consumption

Maximum	≤ 4 VA / 2 W
---------	--------------

### Degree of protection

Front	IP 40
Screw terminals	IP 20

## Weight (Kg) – Dimensions (mm)

Description	Weight	Dimensions		
		Height	Width	Depth
Meter only with packaging	0.4	72	72	65

## Operating & storage temperature

Operating	-25 to +55°C
Storage	-30 to +70°C

## System / Single Phase variables available via RS485 & pulse outputs

Single circuit variables	V, A, W/VA/VAr, PF, kWh, kVArh, Virtual circuit (sum of difference) measurements: W/VA/VAr, PF, kWh, kVArh
--------------------------	--

## Connections

Voltage	Dual screw terminal (Max tightening torque 0.25Nm)
Current inputs	2 x RJ11 (Female) for current connections
Outputs (pulse and RS485 port)	Dual screw terminal (Max tightening torque 0.25Nm)

## Other information

Accuracy	Phase – Neutral Voltage	In the range Un: ± (0,5% RDG).
	Phase – Phase Voltage	In the range Un: ± (1% RDG).
Instant variable readouts	3 DGT	
Energy readouts	Total: 5+2, 6+1 or 7DGT	

# MID Meter Technical Data Information

Main characteristics				
<b>Operating voltage</b>				
Minimum	60 V AC			
Maximum	400 V AC			
<b>Operating frequency</b>				
Minimum	45 Hz			
Maximum	65 Hz			
<b>Power consumption</b>				
Maximum	≤ 2 VA / 1 kW			
<b>Degree of protection</b>				
Front	IP 40			
Screw terminals	IP 20			
Weight (Kg) – Dimensions (mm)				
Description	Weight	Dimensions		
	Kg	Height	Width	Depth
Meter only with packaging	0.4	72	72	65
<b>Operating &amp; storage temperature</b>				
Operating	-25 to +55°C			
Storage	-30 to +70°C			
<b>System / Single Phase variables available via RS485 &amp; pulse outputs</b>				
System variables	W, VAr, Hz, Phase-sequence			
Single phase variables	VLL, VLN, A, PF, THD (A,V, up to the 15 <sup>th</sup> harmonic)			
Energy measurements	Total kWh (imported and exported); kVArh			
<b>Connections</b>				
All connections	Screw connections max torque 0.8Nm			
<b>Other information</b>				
Accuracy	Phase – Neutral Voltage	In the range Un: ± (0,5% RDG +1DGT).		
	Phase – Phase Voltage	In the range Un: ± (1% RDG +1DGT).		
Instant variable readouts	3 DGT			
Energy readouts	Total: 5+2, 6+1 or 7DGT			
Meter Setup	Refer to meter instructions to setup meter. (Note meter CT ratio pre-set to 25/1A).			



Electrium Sales Limited, Walkmill Lane, Cannock, WS11 0XE  
Tel: 01543 455000 Fax: 01543 455001



Waste electrical products should not be disposed of with household waste.  
Please recycle where waste disposal facilities exist.  
Check with your retailer, wholesaler or local authority for recycling advice.